

Sr. No.	Volume/Clause	Query	Clarification required	Reply to Queries
1	General	EMD in form of DD only	You are requested to accept EMD in form of Bank Guarantee also.	Tender Condition remains unchanged
2	General	Liquidated damages @ 0.30% of contract value per day	You are requested to consider liquidated damages @ 0.05% of contract value per day	Tender Condition remains unchanged
3	General	Mobilization advance @ 5% of contract value	You are requested to provide mobilization advance @ 10% of contract value	Tender Condition remains unchanged
4	Part B	Removing and refixing of paver block at various location to connect the fire riser for each building is required. Kindly provide the details in BOQ		No separate items. Rates to be quoted including all necessary civil works. Refer Item Description
5	Part B	Cutting and finishing of RCC floor is required for underlaying the fire line. Kindly give confirmation on scope of work		No separate items. Rates to be quoted including all necessary civil works. Refer Item Description
6	Part B	Pump room details are not provided for external lines. Kindly give inputs on the same.		Refer Attached drawing
7	Part B	Item of Pedestal at ground lvl is not given in the BOQ		No separate items. Rates to be quoted including all necessary civil works. Refer Item Description
8	Part B	Main Fire Pumps, Hanging supports for pipe from slab/floor & Terrace Pump Structural Work is not given in the BOQ		All supports has been included in pipe item.
9	Part B	Details of UGT & Pump Room is not given in the scope of the work.		Refer tender BOQ
10	Part B	All Pumps electrification work (i.e Cable, Lugs, Glands, Earthing, Cable Tray of appropriate size) is not given in the BOQ.		No separate items. All pump electrification works will be included in the Pump items. It is in scope of fire contractor.
18	Part B	GST		All quotes rates should be inclusive of GST

* Rates quoted will be inclusive of all necessary civil works to make the scheme in operations.

* Contractor should submit their detail shop drawings showing electrification, Plumbing works necessary civil works for review and approval.

NOTE: Clarification of pre-bid queries along with necessary amendments (attached) shall be considered as a part of contract documents and to be submitted along with the tender submission with sign and stamp.

DRAW
OUT

4-WAY
FBI

UG - FIRE
FIGHTING WATER
TANK-2
CAPACITY 1,00,000
LTRS.

UG - FIRE
FIGHTING WATER
TANK-1
CAPACITY 1,00,000
LTRS.

